

Emission Test Certificate

Friday, January 20th, 2023

Supplier Clear Form Wall Systems Pty Ltd (26a Harp St, Campsie, NSW, 2194, Australia).

Product name Clear form

Date Tested 18th January 2023 (Tested through Foray Laboratory – NATA Accreditation 1231)


Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	CLEAR FORM
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.094 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m ² /hr	Formaldehyde Emission Rate: 0.010 mg/m ² /hr



Dr. Vyt Garnys
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
Ph.D., B.Eng. (Chemical)
Senior Consultant

Issued Date: 20/1/2023

Expired Date: 20/1/2028

P22110087